

THE FOLLOWING RESOLUTION WAS SPONSORED BY COUNCIL MEMBER ZUCKERMAN; MOTIONED FOR ADOPTION BY COUNCIL MEMBER STRONG-THOMPSON AND SECONDED FOR ADOPTION BY COUNCIL MEMBER VOGELTANZ

RESOLUTION NO. 26-07

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF MANDEVILLE INFORMING THE LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY OF ACTIONS TAKEN BY THE CITY COUNCIL OF THE CITY OF MANDEVILLE REGARDING MUNICIPAL WATER POLLUTION PREVENTION AND RELATED PERMITS

BE IT RESOLVED, that the City of Mandeville informs the Louisiana Department of Environmental Quality that the following actions were taken by the City Council of the City of Mandeville:

1. Reviewed the Municipal Water Pollution Prevention Environmental Audit Report which is attached to this resolution.
2. Set forth the following actions necessary to maintain permit requirements contained in the Louisiana Water Discharge Permit System (LPDES) number LA0038288.
 - a. Continue to provide certified operators for collection and operation by providing 16 hours of training per operator over the next year. This training will be conducted through off-site classes and with the assistance of CES, Inc.
 - b. The City will continue to video and smoke test to identify I&I problem areas.
 - c. Investigate City non-domestic user Ordinance during 2026, consider conducting a non-domestic user survey to identify system users.
 - d. The City will continue to work with its environmental consultant to increase monitoring of Ponds and maintain both wetland discharges as per the LPDES Permit project.
 - e. Monitor wetland discharges and ensure proper wetland loadings for permit compliance.
 - f. Continue maintenance to maintain rock-reed filtration efficiency.
 - g. Continue to supply and consider additional aeration to ensure proper influent treatment and proper biological reduction.
 - h. The City will ensure proper operation of the treatment system through on-going testing, monitoring influents and using the EQ Basin when necessary.
 - i. Continue to monitor and rehab all areas identified as “problem areas” of the collection system and investigate potential solutions to rainfall events causing collection system overflows.
 - j. Continue to upgrade collection system lift stations and investigate methods of minimizing power outages.

- k. Comply with DEQ Lab certification requirements, QA/QC monitoring procedures and new electronic data submission requirements and
- l. Maintain alternative means of disinfection for discharge from wastewater treatment facility to ensure permit compliance.

The resolution being submitted for a vote, the vote thereon was as follows:


AYES: Strong-Thompson, Vogeltanz, Lane, Discon, Zuckerman

NAYS: 0


ABSENT: 0

ABSTENTIONS: 0

And the resolution was declared adopted this 12th day of March 2026.



Alicia Watts
Council Clerk



Jason Zuckerman
Council Chairman